

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING NO.** 3230-0412:101 Page 1 of 1

**CATEGORY:** Leakage Dampers

**LISTEE:** Reed National/Phillips Aire, 7301 International Drive, Holland OH 43528  
Contact: \*Chuck Schneider (419) 865-5000

**DESIGN:** Models S1250, S2250, S2350, S3250, S3350, S4250 and S4350 leakage rated dampers. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation and UL label.

**APPROVAL:** Listed as leakage dampers. Model S1250 rated Class I; Models S2250 and S2350 rated Class II; Models S3250 and S3350 rated Class III; Models S4250 and S4350 rated Class IV.

**XLF:** 3230-1328:106

\*Rev. 08-23-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**AUGUST 19, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager